ATTACHMENT C: APPLICATION REFERRAL RESPONSES

AGENCY	COMMENTS
School Authority	
Rocky View Schools	No response received
Calgary Catholic School District	No concerns
Public Francophone Education	No response received
Catholic Francophone Education	No response received
Province of Alberta	
Alberta Ministry of Environment and Protected Areas	Alberta Forestry & Parks, Lands Division has reviewed the proposal and provides the following comments:
	From reviewing satellite imagery, it appears that wetlands and an unnamed watercourse on the property may be impacted by the subdivision. Under section 3 of the Public Lands Act, the Crown holds right to permanent and naturally occurring bodies of water, rivers, streams, watercourses and lakes. The wetlands should be avoided if the parcel is developed and a minimum 6.0m Environmental Reserve is required to protect the wetland from development.
	It is recommended that a permanence assessment be completed for the wetlands and submitted to the Water Boundaries Unit in Edmonton to determine ownership of the wetlands. If the wetland or unnamed watercourse are determined to be Crown claimable under section 3, it should be surveyed out from the parcel of land. An authorization is required under the Public Lands Act to alter, infill or otherwise impact a Crown claimable wetland or watercourse. An approval may also be required under the Water Act. Please see the Alberta Wetland Policy and the Guide for Assessing Permanence of Wetland Basins for further information.
	The following links are provided for information:
	Alberta Wetland Policy Implementation
	https://www.alberta.ca/alberta-wetland-policy-implementation
	Guide for Assessing Permanence of Wetland Basins
	https://open.alberta.ca/dataset/02b938d2-a26b-41e8-b343- 602b4b6c0c57/resource/98b50b87-6ffe-4c32-ae34- c49e2a3c706c/download/2016-assessingpermanencewetlandbasins- feb2016a.pdf
	Water Boundaries Crown Determination (2026 April 04)
	https://open.alberta.ca/dataset/02b938d2-a26b-41e8-b343- 602b4b6c0c57/resource/22091cbe-dc3e-44b8-a229- 4a7db83c1cbd/download/waterboundariescrowndetermination-apr2016.pdf
	Alberta King's Printer (Public Lands Act, Water Act)
	https://kings-printer.alberta.ca/Laws_Online.cfm

AGENCY	COMMENTS	
Alberta Culture and Community Spirit (Historical Resources)	No response received	
Energy Resources Conservation Board	No response received	
Alberta Health Services	No concerns	
Public Utility		
ATCO Gas	No objection. ATCO Gas' existing and future lines are protected by an existing Utility Right of Way.	
ATCO Pipelines	No objections	
AltaLink Management	No response received	
FortisAlberta	No response received	
TELUS Communications	No concerns	
TransAlta Utilities Ltd.	No response received	
Other External Agencies		
EnCana Corporation	No response received	
Internal Departments		
Recreation, Parks, and Community Support	No comments	
GIS Services	No response received	
Building Services	No response received	
Fire Services & Emergency Management	No concerns	
Capital and Engineering Services	 General: The review of this file is based upon the application submitted. Should the submission material be altered or revised at subsequent development stages these conditions/recommendations may be subject to change to ensure best practices and procedures. As per the application, the applicant is proposing to create a ± 4.05 hectare (± 10.00 acre) parcel (Lot 1) with a ± 4.02 hectare (± 9.94 acre) remainder. 	

AGENCY	(
--------	---

COMMENTS

- The applicant submitted a site plan which shows it meeting the requirement of having at least 1 acre of contiguous geotechnical developable area.
- No development agreement required as part of the proposed subdivision. No road or serviced connection upgrades are being proposed.

Geotechnical:

- Based on a desktop GIS review, slopes steeper than 15% were not identified on the subject lands.
- Engineering has no requirements at this time.

Transportation:

- Access to lot 1 and the remainder lot are provided by existing approaches off Range Road 282.
- As a condition of subdivision, the applicant will be required to upgrade the existing approach on the remainder lot to a mutual gravel approach with a minimum width of 7m in accordance with County Servicing Standards.
 - The applicant/owner shall contact County Road Operations for a pre-construction inspection of the proposed approach locations.
 - The applicant/owner shall contact Road Operations for a postconstruction inspection of the proposed approaches for final acceptance.
- As a condition of subdivision, the applicant will be required to upgrade the existing approach on Lot 1 to a gravel approach with a minimum width of 6.1m in accordance with County Servicing Standards.
 - The applicant/owner shall contact County Road Operations for a pre-construction inspection of the proposed approach locations.
 - The applicant/owner shall contact Road Operations for a postconstruction inspection of the proposed approaches for final acceptance.
- The Transportation off-site levy has not yet been collected on the subject lands. The applicant will not be required to pay the transportation offsite levy, as per the applicable TOL bylaw, as the subject lands are greater than 7.41 acres.

Sanitary/Waste Water:

- The applicant has indicated that Lot 1 and the remainder lot will be serviced by individual septic systems. Lot 1 currently has an existing septic system as per the tentative plan.
- A Level 4 Model Process Assessment Report was submitted by Western Water Resources Inc. on February 7th, 2022, along with a redesignation application (PL20220014). The report clearly states that the remainder lot is suitable for a PSTS and that there are no apparent encumbrances within this lot. The report states that there is space available for a treatment field receiving primary or secondary treated effluent OR a subsurface treatment system receiving secondary treated effluent.

Water Supply and Waterworks:

- The applicant indicated that Lot 1 and the remainder lot will be serviced by water wells. Lot 1 currently has an existing well as per the tentative plan.
- A Phase 1 Groundwater Supply Evaluation Report was submitted by Western Water Resourced Inc. on December 23, 2021, along with a

AGENCY	COMMENTS
	 redesignation application (PL20220014). The report clearly states that the subject lands can sustain an additional water well on the remainder lot and have sufficient groundwater reserves to supply water for future residences within the target quarter section during peak demand periods over the long term. The report also confirms a Total Cumulative Mean Groundwater Production Potential for 24.21 IGPM for the target quarter section. As a condition of subdivision, the applicant must provide an Aquifer Testing (Phase II) report in accordance with County Servicing Standards.
	Storm Water Management:
	 As there is no proposed change in site imperviousness, due to construction of new dwellings or pavement, a significant impact on stormwater management is not expected. No site-specific stormwater implementation plan is warranted at this time. Engineering has no requirements at this time.
	Environmental
	 Should the owner propose development that has a direct impact on any of the wetlands in the subjected lands, the applicant will be responsible for obtaining all required AEP approvals. The applicant submitted a site plan which shows it meeting the requirement of having at least 1 acre of contiguous geotechnical developable area.
Agriculture & Environment Services	If approved, the application of the Agricultural Boundary Design Guidelines wil be beneficial in buffering the residential properties from the agricultural land to the South. The guidelines help mitigate areas of concern including: trespass, litter, pets, noise, providing a visual barrier and concern over fertilizers, dust & normal agricultural practices.

Circulation Period: June 26, 2024 to July 17, 2024.