



ATTACHMENT A: APPLICATION REFERRALS

AGENCY	COMMENTS
Planning and Development, Engineering Services	The subject parcel is located within the Co-operative Stormwater Management Initiative (CSMI) boundary and has a history of flooding issues identified within the 84th Street Master Drainage Plan. Engineering recommends that a drainage easement be registered on the northerly boundary of the subject site to maintain the flexibility for the County to adequately address the drainage issue in the future.
Recreation, Parks and Community Support	<p>The Recreation, Parks and Community Support department has reviewed this application and offer the following comments:</p> <ul style="list-style-type: none">• There are no concerns with this application from a parks, recreation and active transportation perspective.• An undeveloped Municipal Reserve (Grass surfacing, no landscape improvements and no constructed recreational amenities) is located directly north of the subject road allowance.
Transportation Services	Due to the existing drainage issues in this area, Rocky View County may require access to this Right of Way for future flooding response and pumping.

Circulation Period: July 21, 2020 to August 21, 2020.

Agencies that did not respond, expressed no concerns, or were not required for distribution, are not listed.